

CITY OF NEPTUNE BEACH
116 First Street,
Neptune Beach, Florida 32266

Bid No: 2023-02

Title: City Hall Roof Repair

Bid Opening Date & Time: Friday, April 14, 2023, 2:00 P.M. (local time)

Addendum #: One (1)

This addendum is for the purpose of:

Questions/Answers

1. See attached question/answer response sheet.

Date: March 24, 2023

Procurement Manager

This addendum is a part of the above noted solicitation.

ITB# 2023-02	City Hall Roof Repair
QUESTIONS	RESPONSES
1. May we utilize an alternative and install mechanically attached 1/2" Primed Dens Deck with L/W concrete fasteners over the existing L/W concrete. Install Mule Hide Fleece Back 60 mil TPO fully adhered with Helix Max Dual tank	The proposed product is not acceptable as it does not appear applicable for the given wind speeds required per the Drawings and Specifications. A TPO system is not approved.
2. May we utilize an alternative an install TPO membrane Unsecured membrane at all equipment curbs. Install TPO boots at all roof penetrations.	
3. May we utilize an alternative and install TPO drain liners at all roof drains.	