

The City of Neptune Beach 2023 Water Quality Report PWS #2160206

“Quality on Tap”

The City of Neptune Beach is pleased to present you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is groundwater from 3 wells. The wells draw from the Floridan Aquifer. We aerate water for odor removal and chlorinate for disinfection purposes, to provide the highest possible quality water for our customers.

2023 Source Water Assessment

In 2023, the Department of Environmental Protection performed a Source Water Assessment on our system. The assessment was conducted to provide information about any potential sources of contamination in the vicinity of our wells. There was one potential source of contamination identified for this system with low susceptibility levels. The assessment results are available on the FDEP Source Water Assessment and Protection Program website at <https://prodapps.dep.state.fl.us/swapp/>.

We want our valued customers to be informed about their water utility. Should you have any questions about this report or concerning the utility contact our office Monday through Friday, 7:30am -4:00pm and ask for Jack Russell at (904) 270-2419. You may access this report on the City's website <https://www.nbfl.gov>. Our regularly scheduled City Council meetings are held the 1st and 3rd Monday of each month at City Hall at 6:00pm and are open to the public.

The City of Neptune Beach routinely monitors for contaminants in your drinking water according to Federal and State laws, rules, and regulations. Except where indicated otherwise, this report is based on the results of our monitoring for the period of January 1 to December 31, 2023. Data obtained before January 1, 2023, and presented in this report are from the most recent testing done in accordance with the laws, rules, and regulations.

Water Quality Test Results

In the table below, you may find unfamiliar terms and abbreviations. To help you better understand these terms we've provided the following definitions:

- **Maximum Contaminant Level or MCL:** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- **Maximum Contaminant Level Goal or MCLG:** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **Maximum Residual Disinfectant Level or MRDL:** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- **Maximum Residual Disinfectant Level Goal or MRDLG:** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- **Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow. "ND" means not detected and indicates that the substance was not found by laboratory analysis.
- **Parts per million (ppm) or Milligrams per liter (mg/L):** one part by weight of analyte to 1 million parts by weight of the water sample.
- **Parts per billion (ppb) or Micrograms per liter(ug/L):** one part by weight of analyte to 1 billion parts by weight of the water sample

In 2023, The City of Neptune Beach was required to collect two sets of samples to test for Synthetic Organic Contaminants. Incidentally, only one set of sampling was collected in 2023. The second set of sampling was taken, outside of the compliance monitoring period, on January 26, 2024. The results were received on March 25, 2024, which revealed that all of these contaminants were undetected.

Radioactive Contaminants

Contaminant and Unit of Measurement	Dates of sampling (mo/yr)	MCL Violation Y/N	Level Detected	Range of Results	MCLG	MCL	Likely Source of Contamination
Alpha emitters (pCi/L)	5/2023	N	3.20	N/A	0	15	Erosion of natural deposits
Radium 226 + 228 or combined radium (pCi/L)	5/2023	N	1.1	N/A	0	5	Erosion of natural deposits

Inorganic Contaminants

Contaminant and Unit of Measurement	Dates of sampling (mo/yr)	MCL Violation Y/N	Level Detected	Range of Results	MCLG	MCL	Likely Source of Contamination
Barium (ppm)	5/2023	N	0.025	N/A	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Fluoride (ppm)	5/2023	N	0.68	N/A	4	4	Erosion of natural deposits; discharge from fertilizer and aluminum factories. Water additive which promotes strong teeth when at optimum levels between 0.7 and 1.2 ppm
Nickel (ppm)	5/2023	N	0.0014	N/A	N/A	0.14	Pollution from mining and refining operations. Natural occurrence in soil
Sodium (ppm)	5/2023	N	27	N/A	N/A	160	Saltwater intrusion, leaching from soil

Stage 1 Disinfectants and Disinfection Byproducts

Contaminant and Unit of Measurement	Dates of sampling (mo/yr)	MCL Violation Y/N	Level Detected	Range of Results	MCLG or MRDLG	MCL or MRDL	Likely Source of Contamination
Chlorine (ppm)	01/2023-12/2023	N	1.55	1.17-1.88	MRDLG=4	MRDL=4	Water additive used to control microbes

Stage 2 Disinfectants and Disinfection Byproducts

Contaminant and Unit of Measurement	Dates of sampling (mo/yr)	MCL Violation Y/N	Level Detected	Range of Results	MCLG	MCL	Likely Source of Contamination
Haloacetic Acids (HAA5) (ppb)	02/2023 & 11/2023	N	26.19	24.52-26.19	N/A	60	By-product of drinking water disinfection
Total Trihalomethanes (TTHM) (ppb)	03/2023 & 11/2023	N	79.40	60.41-79.40	N/A	80	By-product of drinking water disinfection

Lead and Copper (Tap Water)

Contaminant and Unit of Measurement	Dates of sampling (mo/yr)	AL Violation Y/N	90 th Percentile Result	No. of sampling sites exceeding the AL	MCLG	AL (Action Level)	Likely Source of Contamination
Copper (tap water) (ppm)	06/2023-07/2023	N	0.027	0	1.3	1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead (tap water) (ppb)	06/2023-07/2023	N	0.8	0	0	15	Corrosion of household plumbing systems; erosion of natural deposits

Secondary Contaminants

Contaminant and Unit of Measurement	Dates of sampling (mo/yr)	MCL Violation Y/N	Highest Result	Range of Results	MCLG	MCL	Likely Source of Contamination
Chloride (ppm)	5/2023	N	55	N/A	N/A	250	Natural occurrence from soil leaching
Copper (ppm)	5/2023	N	0.0012	N/A	N/A	1	Corrosion byproduct and natural occurrence from soil leaching
Fluoride (ppm)	5/2023	N	0.68	N/A	N/A	2.0	Erosion of natural deposits; discharge from fertilizer and aluminum factories. Water additive which promotes strong teeth when at the optimum level of 0.7 ppm
Sulfate (ppm)	5/2023	N	140	N/A	N/A	250	Natural occurrence from soil leaching
Odor (Threshold odor number)	5/2023	N	1	N/A	N/A	3	Naturally occurring organics
Total Dissolved Solids (ppm)	5/2023	N	500	N/A	N/A	500	Natural occurrence from soil leaching

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Neptune Beach is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epagov/safewater/lead>.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring

minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.*
- *Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.*
- *Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.*
- *Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also, come from gas stations, urban storm water runoff, and septic systems.*
- *Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.*

To ensure that tap water is safe to drink, the EPA prescribes regulations, which limit the number of certain contaminants in water provided by public water systems. The Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/JCDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

We at the City of Neptune Beach would like you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. If you have any questions or concerns about the information provided, please feel free to call Jack Russell at 904-270-2419.